

ENERGY NORTHWEST

P.O. Box 968 ■ Richland, Washington 99352-0968

October 22, 2002

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

GO2-02-173

Subject: **COLUMBIA GENERATING STATION, DOCKET NO. 50-397,
LICENSE AMENDMENT REQUEST - TECHNICAL SPECIFICATION
CHANGE TO SECTION 5.0, ADMINISTRATIVE CONTROLS**

Dear Sir or Madam:

Pursuant to 50.90, Energy Northwest hereby requests the following amendment: Changes to Technical Specification Section 5.0, Administrative Controls in accordance with NRC approved Technical Specification Task Force (TSTF) item TSTF-258 Revision 4.

Energy Northwest requests approval of the proposed amendment by February 1, 2003 to allow implementation during the next scheduled refueling outage. Once approved the amendment will be implemented within 60 days.

There are no new commitments made in this letter.

In accordance with 10 CFR 50.91, the State of Washington has been provided a copy of this letter.

Should you have any questions or require additional information regarding this matter, please contact Ms. CL Perino, Licensing Manager at (509) 377-2075.

Respectfully,



DK Atkinson
Vice President, Technical Services
Mail Drop PE08

Enclosures:

1. Notarized affidavit
2. Licensee's evaluation of the proposed change

Attachments:

1. Proposed Technical Specification Changes (mark-up)
2. Proposed Technical Specification pages (retyped)
3. Changes to TS Bases pages

cc: EW Merschoff - NRC RIV
BJ Benney - NRC NRR
NRC Sr. Resident Inspector - 988C

DL Williams - BPA/1399
TC Poindexter - Winston & Strawn
JO Luce - EFSEC

A001

STATE OF WASHINGTON)
)
COUNTY OF BENTON)

Subject: Request For Amendment
TS 5.0, Administrative
Controls

I, D. W. Coleman, being duly sworn, subscribe to and say that I am the Acting Vice President, Technical Services for ENERGY NORTHWEST, the applicant herein; that I have the full authority to execute this oath; that I have reviewed the foregoing; and that to the best of my knowledge, information, and belief the statements made in it are true.

DATE October 22, 2002

D. W. Coleman
D. W. Coleman
Acting Vice President, Technical Services

On this date personally appeared before me D. W. Coleman, to me known to be the individual who executed the foregoing instrument, and acknowledged that he signed the same as his free act and deed for the uses and purposes herein mentioned.

GIVEN under my hand and seal this 22nd day of October 2002.



Lori A. Walli
Notary Public in and for the
STATE OF WASHINGTON
Residing at Benton County
My Commission Expires 3-29-05

Enclosure 2

**LICENSE AMENDMENT REQUEST - TECHNICAL SPECIFICATION CHANGE TO
SECTION 5.0, ADMINISTRATIVE CONTROLS**

Page 1 of 7

**Subject: License Amendment Request (LAR) – Technical Specification Change to
Section 5.0, Administrative Controls in Accordance with TSTF-258, Revision 4**

- 1.0 Description**
- 2.0 Proposed Change**
- 3.0 Background**
- 4.0 Technical Analysis**
- 5.0 Regulatory Safety Analysis**
- 6.0 Environmental Consideration**
- 7.0 References**

Enclosure 2

LICENSE AMENDMENT REQUEST - TECHNICAL SPECIFICATION CHANGE TO SECTION 5.0, ADMINISTRATIVE CONTROLS

Page 2 of 7

1.0 Description

The proposed amendment would revise the Columbia Generating Station Technical Specification (TS) Section 5.0, Administrative Controls.

The proposed change is consistent with NRC-approved Industry/Technical Specification Task Force (TSTF) Standard Technical Specification Change Traveler, TSTF-258, Revision 4 (Reference 1).

2.0 Proposed Change

TSTF-258, Revision 4, revises TS Section 5.0, Administrative Controls, to delete specific TS staffing requirement provisions for Reactor Operators (ROs), eliminates TS details for working hour limits, clarifies requirements for the Shift Technical Advisor (STA) position, adds regulatory definitions for Senior Reactor Operators (SROs) and ROs, revises the Radioactive Effluent Control Program, deletes periodic reporting requirements for main steam relief valve openings, and revises radiological area control requirements for radiation areas to be consistent with those specified in 10 CFR 20.1601(c). Please see Attachment 1 for marked-up Columbia Generating Station TS pages.

TSTF-258, Revision 4, is adopted with no variance. Inserts C and D of TSTF-258, Revision 4, involving an update to 10 CFR 20, are already implemented at Columbia Generating Station. This LAR follows the format of the Browns Ferry LAR dated August 28, 2000. The LAR was approved on November 21, 2000.

3.0 Background

3.1 Staffing Requirement Provisions for Reactor Operators

TS Section 5.2.2.b regarding staffing requirements for ROs and SRO presence is deleted. The existing regulatory requirements of 10 CFR 50.54(m)(2)(iii) and 50.54(k) already adequately provide for shift manning requirements for operators.

10 CFR 50.54(m)(2)(iii) requires "when a nuclear power unit is in an operational mode other than cold shutdown or refueling, as defined by the unit's technical specifications, each licensee shall have a person holding a senior operator license for the nuclear power unit in the control room at all times. In addition to this senior operator, a licensed operator or senior operator shall be present at the controls at all times. Further, 50.54(k) requires, "An operator or senior operator licensed pursuant to part 55 of this chapter shall be present at the controls at all times during the operation of the facility."

Hence, the same requirements currently in TS 5.2.2.b are repeated in the referenced CFR sections, which will continue to be met through compliance with these regulations. These CFR provisions need not be reiterated in the TS. Therefore, deletion of TS Section 5.2.2.b is considered an administrative change that removes duplicative CFR requirements from TS.

Enclosure 2

LICENSE AMENDMENT REQUEST - TECHNICAL SPECIFICATION CHANGE TO SECTION 5.0, ADMINISTRATIVE CONTROLS

Page 3 of 7

3.2 Working Hour Limits Details Removal

Specific working hour limits in existing TS Section 5.2.2.e are modified to reference administrative procedures as the means of control working hours. TS 5.2.2.e is renumbered as TS 5.2.2.d.

The inclusion of working hour limits are not required to be in the TS by 10 CFR 50.36(c)(5). Therefore, it is acceptable that requirements for controlling working hours of reactor plant staff be described in site procedures. These administrative procedures require a deliberate decision-making process to minimize the potential for impaired personnel performance. The proposed TS changes are also consistent with the recommendations in the April 9, 1997, letter from C. Grimes (NRC) to J. Davis (NEI).

Additionally, the existing TS provision, "Controls shall be included in the procedures such that individual overtime shall be reviewed monthly by the Plant Manager or his designee to ensure that excessive hours have not been assigned" is being deleted. There is no guidance in Generic Letter 82-12, Nuclear Power Plant Staff Working Hours, that discusses these additional controls. The requirement to have the Plant Manager (or his designee) review individual overtime on a monthly basis is unnecessary since sufficient administrative controls and policies already exist in site procedures. In lieu of this approval requirement, a new TS provision is being added to require a periodic independent review of overtime usage, which will ensure that the administrative procedures for overtime use are being effectively implemented.

The proposed TS change which delegates the details of working hour controls to site processes is considered an administrative change which will continue to provide reasonable assurance that impaired performance caused by excessive working hours will not jeopardize safe plant operation.

3.3 Clarification of Requirements for the Shift Technical Advisor Position

TS Section 5.2.2.g is being revised to eliminate the position title of "Shift Technical Advisor (STA)."

Option 1 of the Commission Policy Statement on Engineering Expertise on Shift can be satisfied by assigning an individual with specified educational qualifications to each operating crew as one of the SROs required by 10 CFR 50.54(m)(2)(i). The existing STS 5.2.2.g wording of "The Shift Technical Advisor (STA) shall provide advisory technical support..." can be easily misinterpreted to infer that separate individuals must fulfill this function. Therefore, the wording is being revised so it is clear that the STA function may be provided by either a separate individual or an individual who also fulfills another role in the shift command structure.

This change is considered administrative since it is a clarification of TS and applicable regulatory requirements will continue to be met.

Enclosure 2

LICENSE AMENDMENT REQUEST - TECHNICAL SPECIFICATION CHANGE TO SECTION 5.0, ADMINISTRATIVE CONTROLS

Page 4 of 7

3.4 Addition of Regulatory Definitions for SRO and RO Positions

A new TS Section 5.3.2 is added which incorporates the regulatory definitions for the SRO and RO positions for the purpose of applying 10 CFR 55.4, which provides the stipulation of, "actively performing the functions of an operator or senior operator means that an individual has a position on the shift crew that requires the individual to be licensed as defined in the facility's technical specifications...." Adding paragraph 5.3.2 ensures that there is no misunderstanding when complying with 10 CFR 55.4 requirements. Adding this paragraph is consistent with the recommendations of the April 9, 1997, letter from C. Grimes (NRC) to J. Davis (NEI).

The minimum staffing requirements stipulated in 10 CFR 50.54(m), for unit members actively performing the functions of an operator or senior operator, can be exceeded by stipulating the enhanced staffing requirements in paragraph 5.3.2. This means the site can take credit for more than the minimum number of watchstanders required by the TS. There are administrative controls which assure that functions and duties are divided and rotated in a manner which provides each watchstander meaningful and significant opportunity to maintain proficiency in the performance of the functions of an RO and/or SRO. This added TS provision is considered an administrative change which does not change any existing manning requirements.

3.5 Revision of the Radioactive Effluent Controls Program to be consistent with the intent of 10 CFR Part 20

TS Section 5.5.4, Radioactive Effluent Controls Program, is being modified to be consistent with 10 CFR Part 20 and TSTF-258, Revision 4 as follows:

In TS 5.5.4.b, the wording regarding liquid effluent releases is modified for consistency with TSTF-258, Revision 4. This is an administrative change and no changes to TS limits are involved.

In TS 5.5.4.g and 5.5.4.j, TS wording regarding the site boundary and doses is modified for consistency with TSTF-258, Revision 4 wording. Also, in 5.5.4.g.1, "whole" body is substituted for "total" body which is more appropriate nomenclature. "Whole body" is used in NUREG-1302, Offsite Dose Calculation Manual Guidance: Standard Radiological Effluent Controls for Boiling Water Reactors, -Generic Letter 89-01, Supplement No. 1. The above changes are administrative and have no effect on application of the TS requirements. Insert C and D of the TSTF have previously been incorporated into Columbia Generating Station TS, therefore, no additional TS changes are required for these two paragraphs.

TS 5.5.4.1 is being added to allow the application of Surveillance Requirements (SRs) provisions 3.0.2 and 3.0.3 to the Radioactive Effluent Controls Program surveillance frequencies. This addition provides scheduling flexibility. SR 3.0.2 permits a 25% extension of the interval specified in the frequency and is generally applied to all SRs including Section

Enclosure 2

LICENSE AMENDMENT REQUEST - TECHNICAL SPECIFICATION CHANGE TO SECTION 5.0, ADMINISTRATIVE CONTROLS

Page 5 of 7

5.0 program-based SRs such as TS 5.5.7, Ventilation Filter Test Program, TS 5.5.8, Explosive Gas and Storage Tank Radioactive Monitoring Program, and TS 5.5.9, Diesel Oil Testing Program. Allowing a 25% extension in the frequency of performing the Radioactive Effluent Controls Program surveillances will have no affect on the outcome of the effluent dose calculations. SR 3.0.3 is added in association with SR 3.0.2 to maintain consistency of TS application. The proposed TS changes maintain the same overall level of effluent control program controls while providing operational flexibility.

3.6 Deletion of Periodic Reporting Requirements for Mainsteam Relief Valve Openings

The reporting of safety and relief valve failures and challenges was originally based on the guidance in NUREG-0694, "TMI-Related Requirements for New Operating Licensees." The guidance of NUREG-0694 states: "Assure that any failure of a Power Operated Relief Valve (PORV) or safety valve to close will be reported to the NRC promptly. All challenges to the PORVs or safety valves should be documented in the annual report." This latter annual reporting requirement was carried forth in STS Section 5.6.4.

NRC Generic Letter 97-02, "Revised Contents of the Monthly Operating Report," requests the submittal of less information in the monthly operating report. The generic letter identifies what needs to be reported to support the NRC Performance Indicator Program, and availability and capacity statistics. The generic letter does not specifically identify the need to report challenges to safety/relief valves. Malfunctions of safety/relief valves during reportable plant transients would be discussed in Licensee Event Reports and the special reporting of safety/relief valve challenges serves no explicit purpose. Therefore, it is acceptable to delete the requirement to provide an annual report of all challenges to the safety/relief valves.

3.7 Revision of Radiological Control Requirements for Radiation Areas to be Consistent with those Specified in 10 CFR 20.1601(c)

TS Section 5.7, High Radiation Area, is being revised in accordance with 10 CFR 20.1601(c) and updates acceptable alternate controls to those provided in 10 CFR 20.1601 as provided in TSTF-258. Columbia Generating Station has previously incorporated many of the clarification changes in TSTF-258, Revision 4.

Existing TS 5.7.1.c, 5.7.1.d, and 5.7.1.e are changed to match the TSTF wording. Clarification is provided to the monitoring requirements for personnel entering the designated High Radiation Areas with dose rates not exceeding 1.0 rem/hour.

Existing TS 5.7.2 is changed to match the wording as recommended by TSTF-258, Revision 4.

LICENSE AMENDMENT REQUEST - TECHNICAL SPECIFICATION CHANGE TO SECTION 5.0, ADMINISTRATIVE CONTROLS

4.0 Technical Analysis

This proposed change is an administrative change. Therefore, no technical analysis is required.

5.0 Regulatory Safety Analysis

Energy Northwest is submitting a request for an amendment to the Columbia Generating Station TS to adopt NRC-approved generic change TSTF-258, Revision 4. This TSTF revises TS Section 5.0, Administrative Controls, to delete specific TS staffing requirement provisions for ROs, eliminates TS details for working hour limits, clarifies requirements for the STA position, adds regulatory definitions for SRO and ROs, revises the Radioactive Effluent Controls Program to be consistent with 10 CFR Part 20, deletes periodic reporting requirements for mainsteam relief valve openings, and revises radiological area control requirements for radiation areas to be consistent with those specified in 10 CFR 20.1601(c).

Energy Northwest has concluded that operation of Columbia Generating Station in accordance with the proposed change to the TS does not involve a significant hazards consideration. Energy Northwest's conclusion is based on its evaluation, in accordance with 10 CFR 50.91(a)(1), of the three standards set forth in 10 CFR 50.92(c).

A. The proposed amendment does not involve a significant increase in the probability or consequences of an accident previously evaluated.

The proposed change is an administrative clarification of existing TS requirements which clarifies and modifies administrative controls in the areas of operator staffing requirements, working hour limits, STA position, Radioactive Effluent Controls Program, periodic reporting requirements for relief valve openings, and radiological control requirements. These changes do not impact the operation, physical configuration, or function of plant equipment or systems. These TS revisions do not affect analysis inputs or mitigation for analyzed accidents and transients. Therefore, the proposed amendment does not involve a significant increase in the probability or consequences of an accident previously evaluated.

B. The proposed amendment does not create the possibility of a new or different kind of accident from any accident previously evaluated.

The proposed change does not involve a physical alteration of the plant, add any new equipment, or require any existing equipment to be operated in a manner different from the present design. The proposed change does not introduce any new modes of plant operation or make any changes to system setpoints. Therefore, the proposed amendment does not create the possibility of a new or different kind of accident from any accident previously evaluated.

LICENSE AMENDMENT REQUEST - TECHNICAL SPECIFICATION CHANGE TO SECTION 5.0, ADMINISTRATIVE CONTROLS

Page 7 of 7

- C. The proposed amendment does not involve a significant reduction in a margin of safety.

The proposed change is administrative in nature and does not involve physical changes to plant structures, systems, or components (SSCs), or the manner in which these SSCs are operated, maintained, modified, tested, or inspected. The proposed change does not involve a change to any safety limit, limiting safety system setting, limiting condition for operation, or design parameters for any SSC. The proposed change does not impact any safety analysis assumptions and does not involve a change in initial conditions, system response times, or other parameters affecting any accident analysis. For these reasons, the proposed amendment does not involve a significant reduction in the margin of safety.

6.0 Environmental Consideration

Energy Northwest has evaluated the proposed amendment against the criteria for identification of licensing and regulatory actions requiring environmental assessment in accordance with 10 CFR 51.21. It has been determined that the proposed change meets the criteria for categorical exclusion as provided for under 10 CFR 51.22(c)(9). This conclusion has been determined because the requested change does not involve a significant hazards consideration, nor does it involve a significant change in the types or significant increase in the amounts of any effluents that may be released off-site.

Accordingly, we have concluded that pursuant to 10 CFR 51.22 (b), an environmental assessment of the proposed changes is not required.

7.0 References

1. TSTF-258, Revision 4, Changes to Technical Specification Section 5.0, Administrative Control.

Attachment 1

**LICENSE AMENDMENT REQUEST - TECHNICAL SPECIFICATION CHANGE TO
SECTION 5.0, ADMINISTRATIVE CONTROLS**

Page 1

Proposed Technical Specification Changes (mark-up)

5.2 Organization

5.2.2 Unit Staff (continued)

b. At least one licensed Reactor Operator (RO) shall be present in the control room when fuel is in the reactor. In addition, while the unit is in MODE 1, 2, or 3, at least one licensed Senior Reactor Operator (SRO) shall be present in the control room.

b → c

and 5.2.2.f.

Shift crew composition may be less than the minimum requirement of 10 CFR 50.54(m)(2)(i) and Specification 5.2.2.a for a period of time not to exceed 2 hours in order to accommodate unexpected absence of on-duty shift crew members provided immediate action is taken to restore the shift crew composition to within the minimum requirements.

c → d

An individual qualified to implement radiation protection procedures shall be on site when fuel is in the reactor. The position may be vacant for not more than 2 hours, in order to provide for unexpected absence, provided immediate action is taken to fill the required position.

d → e

Administrative procedures shall be developed and implemented to limit the working hours of unit staff who perform safety related functions (e.g., licensed SROs, licensed ROs, health physicists, equipment operators, and key maintenance personnel).

Adequate shift coverage shall be maintained without routine heavy use of overtime. The objective shall be to have operating personnel work a nominal 40 hour week while the unit is operating. However, in the event that unforeseen problems require substantial amounts of overtime to be used, or during extended periods of shutdown for refueling, major maintenance, or major plant modification, on a temporary basis the following guidelines shall be followed:

1. An individual should not be permitted to work more than 16 hours straight, excluding shift turnover time;
2. An individual should not be permitted to work more than 16 hours in any 24 hour period, nor more than 24 hours in any 48 hour period, nor more than 72 hours in any 7 day period, all excluding shift turnover time;
3. A break of at least 8 hours should be allowed between work periods, including shift turnover time;

(continued)

5.2 Organization

5.2.2 Unit Staff (continued)

4. Except during extended shutdown periods, the use of overtime should be considered on an individual basis and not for the entire staff on a shift.

INSERT A

Any deviation from the above guidelines shall be authorized in advance by the Plant General Manager or his designee, in accordance with approved administrative procedures, or by higher levels of management, in accordance with established procedures and with documentation of the basis for granting the deviation.

INSERT G

Controls shall be included in the procedures such that individual overtime shall be reviewed monthly by the Plant General Manager or his designee to ensure that excessive hours have not been assigned. Routine deviation from the above guidelines is not authorized.

Working hour

The Operations Manager or Assistant Operations Manager shall hold an SRO license.

(e) →

to the unit operations shift crew

(f) →

An individual

The Shift Technical Advisor (STA) shall provide advisory technical support in the areas of thermal hydraulics, reactor engineering, and plant analysis with regard to the safe operation of the unit. In addition, the STA shall meet the qualifications specified by the Commission Policy Statement on Engineering Expertise on Shift.

This individual

5.0 ADMINISTRATIVE CONTROLS

5.3 Unit Staff Qualifications

- 5.3.1 Each member of the unit staff shall meet or exceed the minimum qualifications of ANSI/ANS N18.1-1971, for comparable positions described in the FSAR, except for:
- a. The Operations Manager, who shall meet the requirements of ANSI/ANS N18.1-1971 with the exception that in lieu of meeting the stated ANSI/ANS requirement to hold a Senior Reactor Operator (SRO) license at the time of appointment to the position, the Operations Manager shall:
 - 1. Hold an SRO license at the time of appointment;
 - 2. Have held an SRO license; or
 - 3. Have been certified for equivalent SRO knowledge; and
 - b. The Radiation Protection Manager, who shall meet or exceed the qualifications of Regulatory Guide 1.8, Revision 1-R, May 1977.
-

INSERT B →

5.5 Programs and Manuals

5.5.3 Post Accident Sampling (continued)

- c. Provisions for maintenance of sampling and analysis equipment.

5.5.4 Radioactive Effluent Controls Program

This program, conforming to 10 CFR 50.36a, provides for the control of radioactive effluents and for maintaining the doses to members of the public from radioactive effluents as low as reasonably achievable. The program shall be contained in the ODCM, shall be implemented by procedures, and shall include remedial actions to be taken whenever the program limits are exceeded. The program shall include the following elements:

- a. Limitations on the functional capability of radioactive liquid and gaseous monitoring instrumentation including surveillance tests and setpoint determination in accordance with the methodology in the ODCM;
- b. Limitations on the concentrations of radioactive material released in liquid effluents ~~from the site~~ to unrestricted areas, conforming to 10 times the concentration values in Appendix B, Table 2, Column 2 to 10 CFR 20.1001 - 20.2402;
- c. Monitoring, sampling, and analysis of radioactive liquid and gaseous effluents pursuant to 10 CFR 20.1302 and with the methodology and parameters in the ODCM;
- d. Limitations on the annual and quarterly doses or dose commitment to a member of the public from radioactive materials in liquid effluents released from each unit to unrestricted areas, conforming to 10 CFR 50, Appendix I;
- e. Determination of cumulative and projected dose contributions from radioactive effluents for the current calendar quarter and current calendar year in accordance with the methodology and parameters in the ODCM at least every 31 days;

(continued)

5.5 Programs and Manuals

5.5.4 Radioactive Effluent Controls Program (continued)

- f. Limitations on the functional capability and use of the liquid and gaseous effluent treatment systems to ensure that appropriate portions of these systems are used to reduce releases of radioactivity when the projected doses in a period of 31 days would exceed 2% of the guidelines for the annual dose or dose commitment, conforming to 10 CFR 50, Appendix I;
- g. Limitations on the dose rate resulting from radioactive material released in gaseous effluents to areas beyond the site boundary shall be limited to the following:
1. For noble gases: less than or equal to a dose rate of 500 mrem/yr to the total body and less than or equal to a dose rate of 3000 mrem/yr to the skin, and
 2. For iodine-131, iodine-133, tritium, and for all radionuclides in particulate form with half lives > 8 days: less than or equal to a dose rate of 1500 mrem/yr to any organ;
- h. Limitations on the annual and quarterly air doses resulting from noble gases released in gaseous effluents from each unit to areas beyond the site boundary, conforming to 10 CFR 50, Appendix I;
- i. Limitations on the annual and quarterly doses to a member of the public from iodine-131, iodine-133, tritium, and all radionuclides in particulate form with half lives > 8 days in gaseous effluents released from each unit to areas beyond the site boundary, conforming to 10 CFR 50, Appendix I;
- j. Limitations on the annual dose or dose commitment to any member of the public due to releases of radioactivity and to radiation from uranium fuel cycle sources, conforming to 40 CFR 190; and , beyond the site boundary,
- k. ... Limitations on venting and purging of the primary containment through the Standby Gas Treatment System to maintain releases as low as reasonably achievable.

INSERT E

(continued)

5.6 Reporting Requirements

5.6.2 Annual Radiological Environmental Operating Report (continued)

report shall be submitted noting and explaining the reasons for the missing results. The missing data shall be submitted in a supplementary report as soon as possible.

5.6.3 Radioactive Effluent Release Report

The Radioactive Effluent Release Report covering the operation of the unit shall be submitted in accordance with 10 CFR 50.36a. The report shall include a summary of the quantities of radioactive liquid and gaseous effluents and solid waste released from the unit. The material provided shall be consistent with the objectives outlined in the ODCM and the Process Control Program and in conformance with 10 CFR 50.36a and 10 CFR 50, Appendix I, Section IV.B.1.

5.6.4 Monthly Operating Reports

Routine reports of operating statistics and shutdown experience, including documentation of all challenges to the safety/relief valves, shall be submitted on a monthly basis no later than the 15th of each month following the calendar month covered by the report.

5.6.5 CORE OPERATING LIMITS REPORT (COLR)

a. Core operating limits shall be established prior to each reload cycle, or prior to any remaining portion of a reload cycle, and shall be documented in the COLR for the following:

1. The APLHGR for Specification 3.2.1;
2. The MCPR for Specification 3.2.2;
3. The LHGR for Specification 3.2.3; and
4. LCO 3.3.1.3, "Oscillation Power Range Monitor (OPRM) Instrumentation."

(continued)

5.0 ADMINISTRATIVE CONTROLS

5.7 High Radiation Area

As provided in paragraph 20.1601(c) of 10 CFR Part 20, the following controls shall be applied to high radiation areas in place of the controls required by paragraph 20.1601(a) and (b) of 10 CFR Part 20.

5.7.1 High Radiation Areas with Dose Rates not Exceeding 1.0 rem/hour (at 30 centimeters from the radiation sources or from any surface penetrated by the radiation)

a. Each entryway to such an area shall be barricaded and conspicuously posted as a high radiation area. Such barricades may be opened as necessary to permit entry or exit of personnel or equipment.

b. Access to, and activities in, each such area shall be controlled by means of a Radiation Work Permit (RWP) or equivalent that includes specification of radiation dose rates in the immediate work area(s) and other appropriate radiation protection equipment and measures.

c. Individuals qualified in radiation protection procedures (e.g., health physics technicians) and personnel continuously escorted by such individuals may be exempted from the requirement for an RWP or equivalent while performing their assigned duties provided that they are following plant radiation protection procedures for entry to, exit from, and work in such areas.

otherwise →

d. Each individual or group entering such an area shall possess:

1. A radiation monitoring device that continuously displays radiation dose rates in the area ("radiation monitoring and indicating device"); ~~or~~
2. A radiation monitoring device that continuously integrates the radiation dose rates in the area and alarms when the device's dose alarm setpoint is reached ("alarmed dosimeter"), with an appropriate alarm setpoint; ~~or~~

(continued)

5.7 High Radiation Area

5.7.1 High Radiation Areas with Dose Rates not Exceeding 1.0 rem/hour (at 30 centimeters from the radiation sources or from any surface penetrated by the radiation) (continued)

3. A radiation monitoring device that continuously transmits dose rate and cumulative dose to a remote receiver monitored by radiation protection personnel responsible for controlling personnel radiation exposure within the area; or

(e.g., pocket ionization chamber or electronic dosimeter)

4. A self-reading dosimeter and,

i. ⁽ⁱ⁾

Be under the surveillance, as specified in the RWP or equivalent, while in the area, of an individual at the work site, qualified in radiation protection procedures, equipped with a radiation monitoring and indicating device who is responsible for controlling personnel radiation exposure within the area, or

ii. ⁽ⁱⁱ⁾

Be under the surveillance, as specified in the RWP or equivalent, while in the area, by means of closed circuit television, of personnel qualified in radiation protection procedures, responsible for controlling personnel radiation exposure in the area,

or personnel continuously escorted by such individuals,

- e. Except for individuals qualified in radiation protection determined procedures, entry into such areas shall be made only after dose rates in the area have been established and entry personnel are knowledgeable of them. These continuously escorted personnel will receive a pre-job briefing prior to entry into such areas. This dose rate determination, knowledge, and pre-job briefing does not require documentation prior to initial entry.

5.7.2

High Radiation Areas with Dose Rates Greater than 1.0 rem/hour (at 30 centimeters from the radiation source or from any surface penetrated by the radiation), but less than 500 rads/hour (at 1 meter from the radiation source or from any surface penetrated by the radiation)

- a. Each entryway to such an area shall be conspicuously posted as a high radiation area and shall be provided with a locked door, gate, or guard, that prevents unauthorized entry, and in addition:

or continuously guarded door or gate

(continued)

5.7 High Radiation Area

5.7.2

High Radiation Areas with Dose Rates Greater than 1.0 rem/hour (at 30 centimeters from the radiation source or from any surface penetrated by the radiation), but less than 500 rads/hour (at 1 meter from the radiation source or from any surface penetrated by the radiation) (continued)

Shift supervisor, radiation protection manager, or his or her designee.

1. All such door and gate keys shall be maintained under the administrative control of the Shift Manager or Health Physics supervisor on duty; and
 2. Doors and gates shall remain locked or guarded except during periods of personnel or equipment entry or exit.
- b. Access to, and activities in, each such area shall be controlled by means of an RWP or equivalent that includes specification of radiation dose rates in the immediate work area(s) and other appropriate radiation protection equipment and measures.
- c. Individuals qualified in radiation protection procedures may be exempted from the requirement for an RWP or equivalent while performing radiation surveys in such areas provided that they are following plant radiation protection procedures for entry to, exit from, and work in such areas.
- d. Each individual (whether alone or in a group) entering such an area shall possess:
1. A radiation monitoring device that continuously integrates the radiation rates in the area and alarms
 - i. An alarming dosimeter with an appropriate alarm setpoint: when the device's dose alarm setpoint is reached, with an appropriate alarm setpoint, or
 2. A radiation monitoring device that continuously transmits dose rate and cumulative dose to a remote receiver monitored by radiation protection personnel responsible for controlling personnel radiation exposure within the area with the means to communicate with and control every individual in the area.
 2. (e.g., pocket ionization chamber or electronic dosimeter)
 3. A self-reading dosimeter and,

- i. Be under the surveillance, as specified in the RWP or equivalent, while in the area, of an individual qualified in radiation protection procedures, equipped with a radiation monitoring and indicating device who is responsible for controlling personnel exposure within the area, or device that continuously displays radiation dose rates in the area;

(continued)

5.7 High Radiation Area

5.7.2 High Radiation Areas with Dose Rates Greater than 1.0 rem/hour (at 30 centimeters from the radiation source or from any surface penetrated by the radiation), but less than 500 rads/hour (at 1 meter from the radiation source or from any surface penetrated by the radiation) (continued)

- ii) Be under the surveillance, as specified in the RWP or equivalent, while in the area, by means of closed circuit television, of personnel qualified in radiation protection procedures, responsible for controlling personnel radiation exposure in the area, and with the means to communicate with and control every individual in the area. or

4. A radiation monitoring and indicating device in those cases where the options of Specification 5.7.2.d.2 and 5.7.2.d.3. above, are impractical or determined to be inconsistent with the "As Low As is Reasonably Achievable" principle.

- or personnel continuously escorted by such individuals,
e. Except for individuals qualified in radiation protection procedures, entry into such areas shall be made only after dose rates in the area have been established and entry personnel are knowledgeable of them. determined

- f. Such individual areas that are within a larger area that is controlled as a high radiation area where no enclosure exists for purpose of locking and where no enclosure can reasonably be constructed around the individual area need not be controlled by a locked door or gate, but shall be barricaded, and conspicuously posted, as a high radiation area, and a conspicuous clearly visible flashing light shall be activated at the area as a warning device.

nor continuously guarded

These continuously escorted personnel will receive a pre-job briefing prior to entry into such areas. This dose rate determination, knowledge, and pre-job briefing does not require documentation prior to initial entry.

In those cases where options 2. and 3., above are impractical or determined to be inconsistent with the "As Low As is Reasonably Achievable" principle, a radiation monitoring device that continuously displays radiation dose rates in the area,

INSERT A

The controls shall include guidelines on working hours that ensure adequate shift coverage shall be maintained without routine heavy use of overtime.

INSERT B

- 5.3.2 For the purpose of 10 CFR 55.4, a licensed Senior Reactor Operator (SRO) and a licensed reactor operator (RO) are those individuals who, in addition to meeting the requirements of TS 5.3.1, perform the functions described in 10 CFR 50.54(m).

Already Implemented at CBS

INSERT C

to ten times the concentration values in Appendix B, Table 2, Column 2 to 10 CFR 20.1001-20.2402.

INSERT D

shall be in accordance with the following:

1. For noble gases: a dose rate ≤ 500 mrem/yr to the whole body and a dose rate ≤ 3000 mrem/yr to the skin, and
2. For iodine-131, iodine-133, tritium, and all radionuclides in particulate form with half-lives greater than 8 days: a dose rate ≤ 1500 mrem/yr to any organ;

INSERT E

The provisions of SR 3.0.2 and SR 3.0.3 are applicable to the Radioactive Effluent Controls Program surveillance frequency.

INSERT G

Controls shall be included in the procedures to require a periodic independent review be conducted to ensure that excessive hours have not been assigned.

Attachment 2

**LICENSE AMENDMENT REQUEST - TECHNICAL SPECIFICATION CHANGE TO
SECTION 5.0, ADMINISTRATIVE CONTROLS**

Page 1

Proposed Technical Specification pages (retyped)

5.0 ADMINISTRATIVE CONTROLS

5.2 Organization

5.2.1 Onsite and Offsite Organizations

Onsite and offsite organizations shall be established for unit operation and corporate management, respectively. The onsite and offsite organizations shall include the positions for activities affecting safety of the nuclear power plant.

- a. Lines of authority, responsibility, and communication shall be defined and established throughout highest management levels, intermediate levels, and all operating organization positions. These relationships shall be documented and updated, as appropriate, in organization charts, functional descriptions of departmental responsibilities and relationships, and job descriptions for key personnel positions, or in equivalent forms of documentation. These requirements shall be documented in the FSAR.
- b. The Plant General Manager shall be responsible for overall safe operation of the plant and shall have control over those onsite activities necessary for safe operation and maintenance of the plant.
- c. The Chief Executive Officer shall have corporate responsibility for overall plant nuclear safety and shall take any measures needed to ensure acceptable performance of the staff in operating, maintaining, and providing technical support to the plant to ensure nuclear safety.
- d. The individuals who train the operating staff, carry out health physics, or perform quality assurance functions may report to the appropriate onsite manager; however, these individuals shall have sufficient organizational freedom to ensure their independence from operating pressures.

5.2.2 Unit Staff

The unit staff organization shall include the following:

- a. At least two Equipment Operators shall be assigned when the unit is in MODE 1, 2, or 3; and at least one Equipment Operator shall be assigned when the unit is in MODE 4 or 5.

(continued)

5.2 Organization

5.2.2 Unit Staff (continued)

- b. Shift crew composition may be less than the minimum requirement of 10 CFR 50.54(m)(2)(i) and 5.2.2.a and 5.2.2.f for a period of time not to exceed 2 hours in order to accommodate unexpected absence of on-duty shift crew members provided immediate action is taken to restore the shift crew composition to within the minimum requirements.
- c. An individual qualified to implement radiation protection procedures shall be on site when fuel is in the reactor. The position may be vacant for not more than 2 hours, in order to provide for unexpected absence, provided immediate action is taken to fill the required position.
- d. Administrative procedures shall be developed and implemented to limit the working hours of personnel who perform safety related functions (e.g., licensed SROs, licensed ROs, health physicists, equipment operators, and key maintenance personnel).

The controls shall include guidelines on working hours that ensure adequate shift coverage shall be maintained without routine heavy use of overtime.

Any deviation from the above guidelines shall be authorized in advance by the Plant General Manager or his designee, in accordance with approved administrative procedures, with documentation of the basis for granting the deviation.

Controls shall be included in the procedures to require a periodic independent review be conducted to ensure that excessive hours have not been assigned. Routine deviation from the working hour guidelines shall not be authorized.

- e. The Operations Manager or Assistant Operations Manager shall hold an SRO license.
 - f. An individual shall provide advisory technical support to the unit operations shift crew in the areas of thermal hydraulics, reactor engineering, and plant analysis with regard to the safe operation of the unit. This individual shall meet the qualifications specified by the Commission Policy Statement on Engineering Expertise on Shift.
-

5.0 ADMINISTRATIVE CONTROLS

5.3 Unit Staff Qualifications

- 5.3.1 Each member of the unit staff shall meet or exceed the minimum qualifications of ANSI/ANS N18.1-1971, for comparable positions described in the FSAR, except for:
- a. The Operations Manager, who shall meet the requirements of ANSI/ANS N18.1-1971 with the exception that in lieu of meeting the stated ANSI/ANS requirement to hold a Senior Reactor Operator (SRO) license at the time of appointment to the position, the Operations Manager shall:
 - 1. Hold an SRO license at the time of appointment;
 - 2. Have held an SRO license; or
 - 3. Have been certified for equivalent SRO knowledge; and
 - b. The Radiation Protection Manager, who shall meet or exceed the qualifications of Regulatory Guide 1.8, Revision 1-R, May 1977.
- 5.3.2 For the purpose of 10 CFR 55.4, a licensed Senior Reactor Operator (SRO) and a licensed Reactor Operator (RO) are those individuals who, in addition to meeting the requirements of TS 5.3.1, perform the functions described in 10 CFR 50.54(m).
-

5.5 Programs and Manuals

5.5.3 Post Accident Sampling (continued)

- c. Provisions for maintenance of sampling and analysis equipment.

5.5.4 Radioactive Effluent Controls Program

This program, conforming to 10 CFR 50.36a, provides for the control of radioactive effluents and for maintaining the doses to members of the public from radioactive effluents as low as reasonably achievable. The program shall be contained in the ODCM, shall be implemented by procedures, and shall include remedial actions to be taken whenever the program limits are exceeded. The program shall include the following elements:

- a. Limitations on the functional capability of radioactive liquid and gaseous monitoring instrumentation including surveillance tests and setpoint determination in accordance with the methodology in the ODCM;
- b. Limitations on the concentrations of radioactive material released in liquid effluents to unrestricted areas, conforming to 10 times the concentration values in Appendix B, Table 2, Column 2 to 10 CFR 20.1001 - 20.2402;
- c. Monitoring, sampling, and analysis of radioactive liquid and gaseous effluents pursuant to 10 CFR 20.1302 and with the methodology and parameters in the ODCM;
- d. Limitations on the annual and quarterly doses or dose commitment to a member of the public from radioactive materials in liquid effluents released from each unit to unrestricted areas, conforming to 10 CFR 50, Appendix I;
- e. Determination of cumulative and projected dose contributions from radioactive effluents for the current calendar quarter and current calendar year in accordance with the methodology and parameters in the ODCM at least every 31 days;

(continued)

5.5 Programs and Manuals

5.5.4 Radioactive Effluent Controls Program (continued)

- f. Limitations on the functional capability and use of the liquid and gaseous effluent treatment systems to ensure that appropriate portions of these systems are used to reduce releases of radioactivity when the projected doses in a period of 31 days would exceed 2% of the guidelines for the annual dose or dose commitment, conforming to 10 CFR 50, Appendix I;
- g. Limitations on the dose rate resulting from radioactive material released in gaseous effluents from the site to areas at or beyond the site boundary shall be limited to the following:
 - 1. For noble gases: less than or equal to a dose rate of 500 mrem/yr to the whole body and less than or equal to a dose rate of 3000 mrem/yr to the skin, and
 - 2. For iodine-131, iodine-133, tritium, and for all radionuclides in particulate form with half lives > 8 days: less than or equal to a dose rate of 1500 mrem/yr to any organ;
- h. Limitations on the annual and quarterly air doses resulting from noble gases released in gaseous effluents from each unit to areas beyond the site boundary, conforming to 10 CFR 50, Appendix I;
- i. Limitations on the annual and quarterly doses to a member of the public from iodine-131, iodine-133, tritium, and all radionuclides in particulate form with half lives > 8 days in gaseous effluents released from each unit to areas beyond the site boundary, conforming to 10 CFR 50, Appendix I;
- j. Limitations on the annual dose or dose commitment to any member of the public, beyond the site boundary, due to releases of radioactivity and to radiation from uranium fuel cycle sources, conforming to 40 CFR 190; and
- k. Limitations on venting and purging of the primary containment through the Standby Gas Treatment System to maintain releases as low as reasonably achievable.

(continued)

5.5 Programs and Manuals (continued)

5.5.4 Radioactive Effluent Controls Program (continued)

1. The provisions of SR 3.0.2 and SR 3.0.3 are applicable to the Radioactive Effluent Controls Program surveillance frequency.

5.5.5 Component Cyclic or Transient Limit

This program provides controls to track the FSAR, Table 3.9-1, Note 1, cyclic and transient occurrences to ensure that components are maintained within the design limits.

5.5.6 Inservice Testing Program

This program provides controls for inservice testing of ASME Code Class 1, 2, and 3 pumps and valves.*

- a. Testing Frequencies specified in Section XI of the ASME Boiler and Pressure Vessel Code and applicable Addenda as follows:

ASME Boiler and Pressure Vessel Code and applicable Addenda terminology for inservice testing activities	Required Frequencies for performing inservice testing activities
Weekly	At least once per 7 days
Monthly	At least once per 31 days
Quarterly or every 3 months	At least once per 92 days
Semiannually or every 6 months	At least once per 184 days
Every 9 months	At least once per 276 days
Yearly or annually	At least once per 366 days
Biennially or every 2 years	At least once per 731 days

(continued)

* The Inservice Testing Program requirement for full stroke exercise testing at each refueling outage for TIP-V-6 shall not be required for the refueling outage conducted in the Spring, 1997. This exception shall expire upon reaching MODE 4 for a plant shutdown of sufficient duration to allow TIP-V-6 testing, or May 15, 1998, whichever occurs first.

5.5 Programs and Manuals

5.5.6 Inservice Testing Program (continued)

- b. The provisions of SR 3.0.2 are applicable to the above required Frequencies for performing inservice testing activities;
- c. The provisions of SR 3.0.3 are applicable to inservice testing activities; and
- d. Nothing in the ASME Boiler and Pressure Vessel Code shall be construed to supersede the requirements of any TS.

5.5.7 Ventilation Filter Testing Program (VFTP)

The VFTP shall establish the required testing of Engineered Safety Feature (ESF) filter ventilation systems.

Tests described in Specification 5.5.7.a and 5.5.7.b shall be performed once per 24 months; after each complete or partial replacement of the HEPA filter train or charcoal adsorber filter; after any structural maintenance on the system housing; and, following significant painting, fire, or chemical release in any ventilation zone communicating with the system while it is in operation.

Tests described in Specification 5.5.7.c shall be performed once per 24 months; after 720 hours of system operation; after any structural maintenance on the system housing; and, following significant painting, fire, or chemical release in any ventilation zone communicating with the system while it is in operation.

Tests described in Specification 5.5.7.d and 5.5.7.e shall be performed once per 24 months.

The provisions of SR 3.0.2 and SR 3.0.3 are applicable to the VFTP test Frequencies.

- a. Demonstrate for each of the ESF systems that an inplace test of the high efficiency particulate air (HEPA) filters shows a penetration and system bypass < 0.05% when tested in accordance with Regulatory Guide 1.52, Revision 2, and ASME N510-1989 at the system flowrate specified below:

(continued)

5.5 Programs and Manuals.

5.5.7 Ventilation Filter Testing Program (VFTP) (continued)

ESF Ventilation System	Flowrate (cfm)
SGT System	4012 to 4902
CREF System	900 to 1100

- b. Demonstrate for each of the ESF systems that an inplace test of the charcoal adsorber shows a penetration and system bypass < 0.05% when tested in accordance with Regulatory Guide 1.52, Revision 2, and ASME N510-1989 at the system flowrate specified below:

ESF Ventilation System	Flowrate (cfm)
SGT System	4012 to 4902
CREF System	900 to 1100

- c. Demonstrate for each of the ESF systems that a laboratory test of a sample of the charcoal adsorber, when obtained as described in Regulatory Guide 1.52, Revision 2, shows the methyl iodide penetration less than the value specified below when tested in accordance with ASTM D3803-1989 at a temperature of 30°C (86°F) and the relative humidity specified below. Testing of the SGT System will also be conducted at a face velocity of 75 feet per minute.

ESF Ventilation System	Penetration (%)	RH (%)
SGT System	0.5	70
CREF System	2.5	70

Allowed tolerances in the above testing parameters of temperature, relative humidity, and face velocity are as specified in ASTM D3803-1989.

- d. Demonstrate for each of the ESF systems that the pressure drop across the combined HEPA filters and the charcoal adsorbers is less than the value specified below when tested at the system flowrate specified below:

ESF Ventilation System	Delta P (inches wg)	Flowrate (cfm)
SGT System	< 8	4012 to 4902
CREF System	< 6	900 to 1100

(continued)

5.5 Programs and Manuals

5.5.7 Ventilation Filter Testing Program (VFTP) (continued)

- e. Demonstrate that the heaters for each of the ESF systems dissipate the nominal value specified below when tested in accordance with ASME N510-1989:

ESF Ventilation System	Wattage (kW)
SGT System	18.6 to 22.8
CREF System	4.5 to 5.5

5.5.8 Explosive Gas and Storage Tank Radioactivity Monitoring Program

This program provides controls for potentially explosive gas mixtures contained in the Main Condenser Offgas Treatment System and the quantity of radioactivity contained in unprotected outdoor liquid storage tanks.

The program shall include:

- a. The limits for concentrations of hydrogen in the Main Condenser Offgas Treatment System and a surveillance program to ensure the limits are maintained. Such limits shall be appropriate to the system's design criteria (i.e., whether or not the system is designed to withstand a hydrogen explosion); and
- b. A surveillance program to ensure that the quantity of radioactivity contained in all outside temporary liquid radwaste tanks that are not surrounded by liners, dikes, or walls, capable of holding the tanks' contents and that do not have tank overflows and surrounding area drains connected to the Liquid Radwaste Treatment System is less than the amount that would result in concentrations greater than the limits of Appendix B, Table 2, Column 2 to 10 CFR 20.1001 - 20.2402, at the nearest potable water supply and the nearest surface water supply in an unrestricted area, in the event of an uncontrolled release of the tanks' contents.

The provisions of SR 3.0.2 and SR 3.0.3 are applicable to the Explosive Gas and Storage Tank Radioactivity Monitoring Program Surveillance Frequencies.

(continued)

5.0 ADMINISTRATIVE CONTROLS

5.6 Reporting Requirements

The following reports shall be submitted in accordance with 10 CFR 50.4.

5.6.1 Occupational Radiation Exposure Report

A tabulation on an annual basis of the number of station, utility, and other personnel (including contractors) for whom monitoring was performed, receiving an annual deep dose equivalent of > 100 mrem and the associated collective deep dose equivalent (reported in man-rem) according to work and job functions (e.g., reactor operations and surveillance, inservice inspection, routine maintenance, special maintenance (describe maintenance), waste processing, and refueling). This tabulation supplements the requirements of 10 CFR 20.2206. The dose assignments to various duty functions may be estimated based on electronic or pocket dosimeter, thermoluminescent dosimeter (TLD), or film badge measurements. Small exposures totalling < 20% of the individual total dose need not be accounted for. In the aggregate, at least 80% of the total whole body dose received from external sources should be assigned to specific major work functions. The report shall be submitted by April 30 of each year.

5.6.2 Annual Radiological Environmental Operating Report

The Annual Radiological Environmental Operating Report covering the operation of the unit during the previous calendar year shall be submitted by May 15 of each year. The report shall include summaries, interpretations, and analyses of trends of the results of the Radiological Environmental Monitoring Program for the reporting period. The material provided shall be consistent with the objectives outlined in the Offsite Dose Calculation Manual (ODCM), and in 10 CFR 50, Appendix I, Sections IV.B.2, IV.B.3, and IV.C.

The Annual Radiological Environmental Operating Report shall include the results of analyses of all radiological environmental samples and of all environmental radiation measurements taken during the period pursuant to the locations specified in the table and figures in the ODCM, as well as summarized and tabulated results of these analyses and measurements in the format of the table in the Radiological Assessment Branch Technical Position, Revision 1, November 1979. In the event that some individual results are not available for inclusion with the report, the

(continued)

5.6 Reporting Requirements

5.6.2 Annual Radiological Environmental Operating Report (continued)

report shall be submitted noting and explaining the reasons for the missing results. The missing data shall be submitted in a supplementary report as soon as possible.

5.6.3 Radioactive Effluent Release Report

The Radioactive Effluent Release Report covering the operation of the unit shall be submitted in accordance with 10 CFR 50.36a. The report shall include a summary of the quantities of radioactive liquid and gaseous effluents and solid waste released from the unit. The material provided shall be consistent with the objectives outlined in the ODCM and the Process Control Program and in conformance with 10 CFR 50.36a and 10 CFR 50, Appendix I, Section IV.B.1.

5.6.4 Monthly Operating Reports

Routine reports of operating statistics and shutdown experience shall be submitted on a monthly basis no later than the 15th of each month following the calendar month covered by the report.

5.6.5 CORE OPERATING LIMITS REPORT (COLR)

- a. Core operating limits shall be established prior to each reload cycle, or prior to any remaining portion of a reload cycle, and shall be documented in the COLR for the following:
 1. The APLHGR for Specification 3.2.1;
 2. The MCPR for Specification 3.2.2;
 3. The LHGR for Specification 3.2.3; and
 4. LCO 3.3.1.3, "Oscillation Power Range Monitor (OPRM) Instrumentation."

(continued)

5.0 ADMINISTRATIVE CONTROLS

5.7 High Radiation Area

As provided in paragraph 20.1601(c) of 10 CFR Part 20, the following controls shall be applied to high radiation areas in place of the controls required by paragraph 20.1601(a) and (b) of 10 CFR Part 20.

5.7.1 High Radiation Areas with Dose Rates not Exceeding 1.0 rem/hour (at 30 centimeters from the radiation sources or from any surface penetrated by the radiation)

- a. Each entryway to such an area shall be barricaded and conspicuously posted as a high radiation area. Such barricades may be opened as necessary to permit entry or exit of personnel or equipment.
- b. Access to, and activities in, each such area shall be controlled by means of a Radiation Work Permit (RWP) or equivalent that includes specification of radiation dose rates in the immediate work area(s) and other appropriate radiation protection equipment and measures.
- c. Individuals qualified in radiation protection procedures and personnel continuously escorted by such individuals may be exempted from the requirement for an RWP or equivalent while performing their assigned duties provided that they are otherwise following plant radiation protection procedures for entry to, exit from, and work in such areas.
- d. Each individual or group entering such an area shall possess:
 1. A radiation monitoring device that continuously displays radiation dose rates in the area; or
 2. A radiation monitoring device that continuously integrates the radiation dose rates in the area and alarms when the device's dose alarm setpoint is reached, with an appropriate alarm setpoint; or

(continued)

5.7 High Radiation Area

5.7.1 High Radiation Areas with Dose Rates not Exceeding 1.0 rem/hour (at 30 centimeters from the radiation sources or from any surface penetrated by the radiation) (continued)

3. A radiation monitoring device that continuously transmits dose rate and cumulative dose to a remote receiver monitored by radiation protection personnel responsible for controlling personnel radiation exposure within the area; or
4. A self-reading dosimeter (e.g., pocket ionization chamber or electronic dosimeter) and,
 - (i) Be under the surveillance, as specified in the RWP or equivalent, while in the area, of an individual qualified in radiation protection procedures, equipped with a radiation monitoring device that continuously displays radiation dose rates in the area; who is responsible for controlling personnel radiation exposure within the area, or
 - (ii) Be under the surveillance, as specified in the RWP or equivalent, while in the area, by means of closed circuit television, of personnel qualified in radiation protection procedures, responsible for controlling personnel radiation exposure in the area, and with the means to communicate with individuals in the area who are covered by such surveillance.
- e. Except for individuals qualified in radiation protection procedures, or personnel continuously escorted by such individuals, entry into such areas shall be made only after dose rates in the area have been determined and entry personnel are knowledgeable of them. These continuously escorted personnel will receive a pre-job briefing prior to entry into such areas. This dose rate determination, knowledge, and pre-job briefing dose not require documentation prior to initial entry.

(continued)

5.7 High Radiation Area

5.7.2 High Radiation Areas with Dose Rates Greater than 1.0 rem/hour (at 30 centimeters from the radiation source or from any surface penetrated by the radiation), but less than 500 rads/hour (at 1 meter from the radiation source or from any surface penetrated by the radiation)

- a. Each entryway to such an area shall be conspicuously posted as a high radiation area and shall be provided with a locked or continuously guarded door or gate that prevents unauthorized entry, and in addition:
 1. All such door and gate keys shall be maintained under the administrative control of the Shift Supervisor, Radiation Protection Manager, or his or her designee.
 2. Doors and gates shall remain locked except during periods of personnel or equipment entry or exit.
- b. Access to, and activities in, each such area shall be controlled by means of an RWP or equivalent that includes specification of radiation dose rates in the immediate work area(s) and other appropriate radiation protection equipment and measures.
- c. Individuals qualified in radiation protection procedures may be exempted from the requirement for an RWP or equivalent while performing radiation surveys in such areas provided that they are otherwise following plant radiation protection procedures for entry to, exit from, and work in such areas.
- d. Each individual or group entering such an area shall possess:
 1. A radiation monitoring device that continuously integrates the radiation rates in the area and alarms when the device's dose alarm setpoint is reached, with an appropriate alarm setpoint, or
 2. A radiation monitoring device that continuously transmits dose rate and cumulative dose to a remote receiver monitored by radiation protection personnel responsible for controlling personnel radiation exposure within the area with the means to communicate with and control every individual in the area, or

(continued)

5.7 High Radiation Area

5.7.2 High Radiation Areas with Dose Rates Greater than 1.0 rem/hour (at 30 centimeters from the radiation source or from any surface penetrated by the radiation), but less than 500 rads/hour (at 1 meter from the radiation source or from any surface penetrated by the radiation) (continued)

3. A self-reading dosimeter (e.g., pocket ionization chamber or electronic dosimeter) and,
 - (i) Be under the surveillance, as specified in the RWP or equivalent, while in the area, of an individual qualified in radiation protection procedures, equipped with a radiation monitoring device that continuously displays radiation dose rates in the area; who is responsible for controlling personnel exposure within the area, or
 - (ii) Be under the surveillance, as specified in the RWP or equivalent, while in the area, by means of closed circuit television, of personnel qualified in radiation protection procedures, responsible for controlling personnel radiation exposure in the area, and with the means to communicate with and control every individual in the area.
4. In those cases where options 2. and 3., above are impractical or determined to be inconsistent with the "As Low As is Reasonably Achievable" principle, a radiation monitoring device that continuously displays radiation dose rates in the area.
- e. Except for individuals qualified in radiation protection procedures, or personnel continuously escorted by such individuals, entry into such areas shall be made only after dose rates in the area have been determined and entry personnel are knowledgeable of them. These continuously escorted personnel will receive a pre-job briefing prior to entry into such areas. This dose rate determination, knowledge, and pre-job briefing does not require documentation prior to initial entry.

(continued)

5.7 High Radiation Area

5.7.2 High Radiation Areas with Dose Rates Greater than 1.0 rem/hour (at 30 centimeters from the radiation source or from any surface penetrated by the radiation), but less than 500 rads/hour (at 1 meter from the radiation source or from any surface penetrated by the radiation) (continued)

- f. Such individual areas that are within a larger area where no enclosure exists for purpose of locking and where no enclosure can reasonably be constructed around the individual area need not be controlled by a locked door or gate, nor continuously guarded, but shall be barricaded, conspicuously posted, and a clearly visible flashing light shall be activated at the area as a warning device.
-

Attachment 3

**LICENSE AMENDMENT REQUEST - TECHNICAL SPECIFICATION CHANGE TO
SECTION 5.0, ADMINISTRATIVE CONTROLS**

Page 1

Changes to TS Bases Pages

BASES (continued)

ACTIONS

A.1 and A.2

With one or more OPERABLE control rods not in compliance with the prescribed control rod sequence, action may be taken to either correct the control rod pattern or declare the associated control rods inoperable within 8 hours. Noncompliance with the prescribed sequence may be the result of "double notching," drifting from a control rod drive cooling water transient, leaking scram valves, or a power reduction to $\leq 10\%$ RTP before establishing the correct control rod pattern. The number of OPERABLE control rods not in compliance with the prescribed sequence is limited to eight to prevent the operator from attempting to correct a control rod pattern that significantly deviates from the prescribed sequence.

Required Action A.1 is modified by a Note, which allows the RWM to be bypassed to allow the affected control rods to be returned to their correct position. LCO 3.3.2.1 requires verification of control rod movement by a second licensed operator (Reactor Operator or Senior Reactor Operator) or by a qualified member of the technical staff (e.g., a qualified shift technical advisor or reactor engineer). This ensures that the control rods will be moved to the correct position. A control rod not in compliance with the prescribed sequence is not considered inoperable except as required by Required Action A.2. The allowed Completion Time of 8 hours is reasonable, considering the restrictions on the number of allowed out of sequence control rods and the low probability of a CRDA occurring during the time the control rods are out of sequence.

B.1 and B.2

If nine or more OPERABLE control rods are out of sequence, the control rod pattern significantly deviates from the prescribed sequence. Control rod withdrawal should be suspended immediately to prevent the potential for further deviation from the prescribed sequence. Control rod insertion to correct control rods withdrawn beyond their allowed position is allowed since, in general, insertion of control rods has less impact on control rod worth than withdrawals have. Required Action B.1 is modified by a Note that allows the RWM to be bypassed to allow the affected control rods to be returned to their correct position.

(continued)

BASES

ACTIONS B.1 and B.2 (continued)

LCO 3.3.2.1 requires verification of control rod movement by a second licensed operator (Reactor Operator or Senior Reactor Operator) or by a qualified member of the technical staff (e.g., a qualified shift technical advisor or reactor engineer).

With nine or more OPERABLE control rods not in compliance with BPWS, the reactor mode switch must be placed in the shutdown position within 1 hour. With the reactor mode switch in shutdown, the reactor is shut down, and therefore does not meet the applicability requirements of this LCO. The allowed Completion Time of 1 hour is reasonable to allow insertion of control rods to restore compliance, and is appropriate relative to the low probability of a CRDA occurring with the control rods out of sequence.

SURVEILLANCE SR 3.1.6.1
REQUIREMENTS

The control rod pattern is verified to be in compliance with the BPWS at a 24 hour Frequency, ensuring the assumptions of the CRDA analyses are met. The 24 hour Frequency of this Surveillance was developed considering that the primary check of the control rod pattern compliance with the BPWS is performed by the RWM (LCO 3.3.2.1). The RWM provides control rod blocks to enforce the required control rod sequence and is required to be OPERABLE when operating at $\leq 10\%$ RTP.

- REFERENCES
1. CE-NPSD-883-P, "Columbia Cycle 16 Reload Licensing Report," March 2001.
 2. Letter from T.A. Pickens (BWROG) to G.C. Laines (NRC), "Amendment 17 to General Electric Licensing Topical Report NEDE-24011-P-A," BWROG-8644, August 15, 1988.
 3. FSAR, Section 15.F.4.3.
 4. CENPD-284-P-A, "Control Rod Drop Accident Analysis Methodology for Boiling Water Reactors: Summary and Qualification," July 1996.

(continued)

BASES

ACTIONS C.1, C.2.1.1, C.2.1.2, and C.2.2 (continued)

Required Action C.2.2 allows for the RWM Function to be performed manually and requires a double check of compliance with the prescribed rod sequence by a second licensed operator (Reactor Operator or Senior Reactor Operator) or other qualified member of the technical staff (e.g., a qualified shift technical advisor or reactor engineer).

The RWM may be bypassed under these conditions to allow continued operations. In addition, Required Actions of LCO 3.1.3 and LCO 3.1.6 may require bypassing the RWM, during which time the RWM must be considered inoperable with Condition C entered and its Required Actions taken.

D.1

With the RWM inoperable during a reactor shutdown, the operator is still capable of enforcing the prescribed control rod sequence. Required Action D.1 allows for the RWM Function to be performed manually and requires a double check of compliance with the prescribed rod sequence by a second licensed operator (Reactor Operator or Senior Reactor Operator) or other qualified member of the technical staff (e.g., a qualified shift technical advisor or reactor engineer). The RWM may be bypassed under these conditions to allow the reactor shutdown to continue.

E.1 and E.2

With one Reactor Mode Switch—Shutdown Position control rod withdrawal block channel inoperable, the remaining OPERABLE channel is adequate to perform the control rod withdrawal block function. However, since the Required Actions are consistent with the normal action of an OPERABLE Reactor Mode Switch—Shutdown Position Function (i.e., maintaining all control rods inserted), there is no distinction between having one or two channels inoperable.

In both cases (one or both channels inoperable), suspending all control rod withdrawal and initiating action to fully insert all insertable control rods in core cells containing one or more fuel assemblies will ensure that the core is

(continued)

BASES (continued)

SURVEILLANCE
REQUIREMENTS

SR 3.10.2.1 and SR 3.10.2.2

Meeting the requirements of this Special Operations LCO maintains operation consistent with or conservative to operating with the reactor mode switch in the shutdown position (or the refuel position for MODE 5). The functions of the reactor mode switch interlocks that are not in effect, due to the testing in progress, are adequately compensated for by the Special Operations LCO requirements. The administrative controls are to be periodically verified to ensure that the operational requirements continue to be met. In addition, the all rods fully inserted Surveillance (SR 3.10.2.1) must be verified by a second licensed operator (Reactor Operator or Senior Reactor Operator) or other qualified member of the technical staff (e.g., a qualified shift technical advisor or reactor engineer). The Surveillances performed at the 12 hour and 24 hour Frequencies are intended to provide appropriate assurance that each operating shift is aware of and verify compliance with these Special Operations LCO requirements.

REFERENCES

1. FSAR, Section 7.2.
2. - FSAR, Section 15.4.1.1.
3. 10 CFR 50.36(c)(2)(ii).

BASES

APPLICABLE
SAFETY ANALYSES
(continued)

As described in LCO 3.0.7, compliance with Special Operations LCOs is optional, and therefore, no criteria of Reference 2 apply. Special Operations LCOs provide flexibility to perform certain operations by appropriately modifying requirements of other LCOs. A discussion of the criteria satisfied for the other LCOs is provided in their respective Bases.

LCO

As described in LCO 3.0.7, compliance with this Special Operations LCO is optional. Control rod testing may be performed in compliance with the prescribed sequences of LCO 3.1.6, and during these tests, no exceptions to the requirements of LCO 3.1.6 are necessary. For testing performed with a sequence not in compliance with LCO 3.1.6, the requirements of LCO 3.1.6 may be suspended, provided additional administrative controls are placed on the test to ensure that the assumptions of the special safety analysis for the test sequence are satisfied. Assurance that the test sequence is followed can be provided by either programming the test sequence into the RWM, with conformance verified as specified in SR 3.3.2.1.8 and allowing the RWM to monitor control rod withdrawal and provide appropriate control rod blocks if necessary, or by verifying conformance to the approved test sequence by a second licensed operator (Reactor Operator or Senior Reactor Operator) or other qualified member of the technical staff (e.g., a qualified shift technical advisor or reactor engineer). These controls are consistent with those normally applied to operation in the startup range as defined in the SRs and ACTIONS of LCO 3.3.2.1, "Control Rod Block Instrumentation."

APPLICABILITY

Control rod testing, while in MODES 1 and 2 with THERMAL POWER greater than 10% RTP, is adequately controlled by the existing LCOs on power distribution limits and control rod block instrumentation. Control rod movement during these conditions is not restricted to prescribed sequences and can be performed within the constraints of LCO 3.2.1, "AVERAGE PLANAR LINEAR HEAT GENERATION RATE (APLHGR)," LCO 3.2.2, "MINIMUM CRITICAL POWER RATIO (MCPR)," LCO 3.2.3, "LINEAR HEAT GENERATION RATE (LHGR)," and LCO 3.3.2.1. With THERMAL POWER less than or equal to 10% RTP, the provisions of this Special Operations LCO are necessary to perform special tests that are not in conformance with the prescribed

(continued)

BASES

APPLICABILITY (continued)	control rod sequences of LCO 3.1.6. While in MODES 3 and 4, control rod withdrawal is only allowed if performed in accordance with Special Operations LCO 3.10.3, "Single Control Rod Withdrawal—Hot Shutdown" or Special Operations LCO 3.10.4, "Single Control Rod Withdrawal—Cold Shutdown," which provide adequate controls to ensure that the assumptions of the safety analyses of References 1 and 2 are satisfied. During these Special Operations and while in MODE 5, the one-rod-out interlock (LCO 3.9.2, "Refuel Position One-Rod-Out Interlock) and scram functions (LCO 3.3.1.1, "Reactor Protection System (RPS) Instrumentation," and LCO 3.9.5, "Control Rod OPERABILITY—Refueling"), or the added administrative controls prescribed in the applicable Special Operations LCOs, minimize potential reactivity excursions.
------------------------------	--

ACTIONS

A.1

With the requirements of the LCO not met (e.g., the control rod pattern not in compliance with the special test sequence, the sequence is improperly loaded in the RWM), the testing is required to be immediately suspended. Upon suspension of the special test, the provisions of LCO 3.1.6 are no longer excepted, and appropriate actions are to be taken either to restore the control rod sequence to the prescribed sequence of LCO 3.1.6, or to shut down the reactor, if required by LCO 3.1.6.

SURVEILLANCE
REQUIREMENTS

SR 3.10.7.1

With the special test sequence not programmed into the RWM, a second licensed operator (Reactor Operator or Senior Reactor Operator) or other qualified member of the technical staff (e.g., a qualified shift technical advisor or reactor engineer) is required to verify conformance with the approved sequence for the test. This verification must be performed during control rod movement to prevent deviations from the specified sequence. A Note is added to indicate that this Surveillance does not need to be met if SR 3.10.7.2 is satisfied.

(continued)

BASES

LCO
(continued)

must be verified by a second licensed operator (Reactor Operator or Senior Reactor Operator) or other qualified member of the technical staff (e.g., a qualified shift technical advisor or reactor engineer). To provide additional protection against an inadvertent criticality, control rod withdrawals that do not conform to the banked position withdrawal sequence specified in LCO 3.1.6, "Rod Pattern Control" (i.e., out of sequence control rod withdrawals) must be made in the notched withdrawal mode to minimize the potential reactivity insertion associated with each movement. Coupling integrity of withdrawn control rods is required to minimize the probability of a CRDA and ensure proper functioning of the withdrawn control rods, if they are required to scram. Because the reactor vessel head may be removed during these tests, no other CORE ALTERATIONS may be in progress. Furthermore, since the control rod scram function with the RCS at atmospheric pressure relies solely on the CRD accumulator, it is essential that the CRD charging water header remain pressurized. This Special Operations LCO then allows changing the Table 1.1-1 reactor mode switch position requirements to include the startup/hot standby position, such that the SDM tests may be performed while in MODE 5.

APPLICABILITY

These SDM test Special Operations requirements are only applicable if the SDM tests are to be performed while in MODE 5 with the reactor vessel head removed or the head bolts not fully tensioned. Additional requirements during these tests to enforce control rod withdrawal sequences and restrict other CORE ALTERATIONS provide protection against potential reactivity excursions. Operations in all other MODES are unaffected by this LCO.

ACTIONS

A.1

With one or more control rods discovered uncoupled during this Special Operation, a controlled insertion of each uncoupled control rod is required; either to attempt recoupling, or to preclude a control rod drop. This controlled insertion is preferred since, if the control rod fails to follow the drive as it is withdrawn (i.e., is "stuck" in an inserted position), placing the reactor mode switch in the shutdown position per Required Action B.1 could cause substantial secondary damage. If recoupling is

(continued)

BASES (continued)

SURVEILLANCE
REQUIREMENTS

SR 3.10.8.1, SR 3.10.8.2, and SR 3.10.8.3

LCO 3.3.1.1, Functions 2.a and 2.d, made applicable in this Special Operations LCO, are required to have applicable Surveillances met to establish that this Special Operations LCO is being met (SR 3.10.8.1). However, the control rod withdrawal sequences during the SDM tests may be enforced by the RWM (LCO 3.3.2.1, Function 2, MODE 2 requirements) or by a second licensed operator (Reactor Operator or Senior Reactor Operator) or other qualified member of the technical staff (e.g., a qualified shift technical advisor or reactor engineer). As noted, either the applicable SRS for the RWM (LCO 3.3.2.1) must be satisfied according to the applicable Frequencies (SR 3.10.8.2), or the proper movement of control rods must be verified (SR 3.10.8.3). This latter verification (i.e., SR 3.10.8.3) must be performed during control rod movement to prevent deviations from the specified sequence. These Surveillances provide adequate assurance that the specified test sequence is being followed.

SR 3.10.8.4

Periodic verification of the administrative controls established by this LCO will ensure that the reactor is operated within the bounds of the safety analysis. The 12 hour Frequency is intended to provide appropriate assurance that each operating shift is aware of and verifies compliance with these Special Operations LCO requirements. --

SR 3.10.8.5

Coupling verification is performed to ensure the control rod is connected to the control rod drive mechanism and will perform its intended function when necessary. The verification is required to be performed any time a control rod is withdrawn to the "full-out" notch position or prior to declaring the control rod OPERABLE after work on the control rod or CRD System that could affect coupling. This Frequency is acceptable, considering the low probability that a control rod will become uncoupled when it is not being moved as well as operating experience related to uncoupling events.

(continued)